

List of Amendments

Part A

No. of Amendment	Location	Content of Amendment	Remarks
Amendment 1	3.2.1.3	General amendment for clarification.	To incorporate requirement of WSD Circular Letter No. 7/2024
Amendment 2	Table 3.2.1.5.5	General amendment for clarification.	
Amendment 3	3.2.2.6	General amendment for clarification.	
Amendment 4	4.1.1.3	New requirement on the use of color, pipe material and size for portable and non-portable water at the same location	
Amendment 5	4.1.1.4	New requirement on provision of fullway gate valve close to the Government water supply connection	
Amendment 6	4.3.5.7	New requirement on providing a tee-branch valve for all flushing pipes at locations where the valve could be reached from the premises and as close to the common pipe as practicable	
Amendment 7	6.2.1.1.5	New requirement on providing and maintaining safe access to water cistern	
Amendment 8	6.2.2.6	To provide requirement of the sealing of entry points of water tanks	To incorporate requirement of WSD Circular Letter No. 8/2022
Amendment 9	6.2.4.4.10	To provide standards for the mesh installed on the vent pipe and the overflow pipe cap of potable fresh water tank	
Amendment 10	6.8.2.2, 6.8.2.4, 6.8.2.5, Table	To provide new requirement on backflow prevention requirement on washing machines and dishwashers	To incorporate requirement of WSD Circular Letter

No. of Amendment	Location	Content of Amendment	Remarks
	4.2.3.7.2, Fig 34		No. 2/2024

Part B

No. of Amendment	Location	Content of Amendment	Remarks
Amendment 1	B2.3	Leaching Test for General Acceptance (GA) Application of Taps and Mixers - Alternative Route	To incorporate requirement of WSD Circular Letter No. 7/2024
Amendment 2	B5	Test item for Long Screw Connector/Flange Adaptor is added	
Amendment 3	Note 5 of Table B7	General amendment for clarification	