

List of Amendments

Part A

| No. of Amendment | Location | Content of Amendment | Remarks |
|------------------|--|--|--|
| Amendment 1 | 3.2.1.3 | General amendment for clarification. | To incorporate requirement of WSD Circular Letter No. 7/2024 |
| Amendment 2 | Table 3.2.1.5.5 | General amendment for clarification. | |
| Amendment 3 | 3.2.2.6 | General amendment for clarification. | |
| Amendment 4 | 4.1.1.3 | New requirement on the use of color, pipe material and size for portable and non-portable water at the same location | |
| Amendment 5 | 4.1.1.4 | New requirement on provision of fullway gate valve close to the Government water supply connection | |
| Amendment 6 | 4.3.5.7 | New requirement on providing a valve on the flushing main outside of all individual domestic and commercial unit | |
| Amendment 7 | 6.2.1.1.5 | New requirement on providing and maintaining safe access to water cistern | |
| Amendment 8 | 6.2.2.6 | To provide requirement of the sealing of entry points of water tanks | To incorporate requirement of WSD Circular Letter No. 8/2022 |
| Amendment 9 | 6.2.4.4.10 | To provide standards for the mesh installed on the vent pipe and the overflow pipe cap of potable fresh water tank | |
| Amendment 10 | 6.8.2.2, 6.8.2.4, 6.8.2.5, Table 4.2.3.7.2, Fig 34 | To provide new requirement on backflow prevention requirement on washing machines and dishwashers | To incorporate requirement of WSD Circular Letter No. 2/2024 |

Part B

| No. of Amendment | Location | Content of Amendment | Remarks |
|-------------------------|--------------------|--|--|
| Amendment 1 | B2.3 | Leaching Test for General Acceptance (GA) Application of Taps and Mixers - Alternative Route | To incorporate requirement of WSD Circular Letter No. 7/2024 |
| Amendment 2 | B5 | Test item for Long Screw Connector/Flange Adaptor is added | |
| Amendment 3 | Note 5 of Table B7 | General amendment for clarification | |