

Water Supplies Department
Water Quality Objectives of Salt Water for Flushing Supply
 水務署
 沖廁用鹹水水質指標

Parameter 參數	Unit 單位	Water Quality Objective Value 水質指標值
Colour 色度	Hazen Unit	< 40
Turbidity 混濁度	NTU	< 20
Threshold Odour Number 氣味閾值	--	< 100
Ammoniacal Nitrogen 氨氮	mg/L 毫克/公升	< 1
Total Suspended Solids 總懸浮固體	mg/L 毫克/公升	< 20
Dissolved Oxygen 溶解氧	mg/L 毫克/公升	> 2
5-day Biochemical Oxygen Demand 五日生化需氧量	mg/L 毫克/公升	< 10
Synthetic Detergents 合成清潔劑	mg/L 毫克/公升	< 5
<i>Escherichia. coli</i> 埃希氏大腸桿菌	cfu/100 mL 菌落數/100 毫升	< 5 000

Note 註 :

mg/L: milligram per liter

cfu: colony forming unit