

**Water Supplies Department**  
**Water Quality Standards for Recycled Water**  
 水務署  
 循環再用水水質標準

Parameter 參數	Unit 單位	Water Quality Standard Value 水質標準值
Colour 色度	Hazen unit	$\leq 20$
Turbidity 混濁度	NTU	$\leq 5$
Threshold Odour Number 氣味閾值	--	$\leq 100$
Ammoniacal Nitrogen 氨氮	mg/L 毫克/公升	$\leq 1$
Total Suspended Solids 總懸浮固體	mg/L 毫克/公升	$\leq 5$
Dissolved Oxygen 溶解氧	mg/L 毫克/公升	$\geq 2$
5-day Biochemical Oxygen Demand 五日生化需氧量	mg/L 毫克/公升	$\leq 10$
Synthetic Detergents 合成清潔劑	mg/L 毫克/公升	$\leq 5$
<i>Escherichia. coli</i> 埃希氏大腸桿菌	cfu/100 mL 菌落數/100 毫升	0
Total Residual Chlorine 總餘氯	mg/L 毫克/公升	$\geq 0.2$
pH 酸鹼值	--	6 - 9

Note 註：

mg/L: milligram per liter

cfu: colony forming unit