



水務署

Water Supplies Department

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong

電子郵遞
e-mail wsdinfo@wsd.gov.hk

電話
Telephone 2829 4355

圖文傳真
Facsimile 2824 0578

檔號
Reference (4) in WSD 3321/16 Pt.1 T/J(1337)

6 October 2016

Approval of "MITY" Check Valves

Your letters both ref. WSD/AP-19092016-1 dated 19 September 2016 and 23 September 2016 refer.

Brand	Size	Nutek Test Report Ref.	Issuance Date
Mity	DN50	J20593A	13 September 2016
Mity	DN65	J20593B	13 September 2016
Mity	DN80	J20593C	13 September 2016
Mity	DN100	J20593D	13 September 2016
Mity	DN150	J20593E	13 September 2016
Mity	DN200	J20593F	13 September 2016

Having considered the above test reports issued by the Nutek Systems (HK) Ltd., this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.



Name of Manufacturer: Yue Hing Machine Factory Ltd.

Country of Origin: China

Brand: Mity

Details of Fittings: Cast iron wafer type silent check valve (with epoxy coating under WRAS approval no. 1410522)

Sizes: DN50, 65, 80, 100, 150, 200

Body Markings:  size in inch 150 

Expiry Date: 31 October 2019

This Authority hereby permits the use of the above fittings in fresh water plumbing systems subject to full adherence to Waterworks installation requirements. On the other hand, the installation of the above fittings in flushing water plumbing systems and fire services may be allowed subject to the compliance of the relevant Waterworks requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fail to meet that of the approved samples or if the fittings are found to be unsuitable for use in fresh water plumbing systems.

For the use of the fittings in any project, the Acceptance Reference Number at the bottom of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 2294 2656.

Yours faithfully,



(CHAN Chung Kun)
for Water Authority

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only

